

RFP-TC1015 Addendum #2 - 9/29/2011

Addendum 2.1

TCC is amending RFP-TC1015 to REMOVE/EXCLUDE all horizontal ladder racks from RFP-TC1015. These ladder racks are being installed by the general contractor.

Please see drawing E304_HorizontalLadderRacks.pdf on
<http://www.lowershore.org/NewFacility/RFPs/TCCNetworkCabling.aspx>

8.1.4.1.1. – Remove

8.1.4.2.1. – Remove

Replace 8.1.4.5.1. with the following

8.1.4.5.1. – the vendor will supply a ladder rack system extending from the raised floor near the entrance to the room, up the wall and interface with the existing horizontal ladder rack.